



JABATAN KERJA RAYA MALAYSIA
CAWANGAN KEJURUTERAAN ELEKTRIK
UNIT PENSIJILAN BAHAN & STANDARD

TECHNICAL INFORMATION

RIGID HIGH IMPACT PVC CONDUIT &
CONDUIT FITTINGS

A. COMPANY INFORMATION						
COMPANY NAME :						
ADDRESS :					TELEPHONE NO :	
					FAX NO :	
		COMPANY EMAIL :				
ISO CERTIFIED COMPANY				REGISTRATION NO:		SCOPE:
1. ISO 9001	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO
2. ISO 14001	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO
3. ISO 50001	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO
4. ISO	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO
B. PRODUCT INFORMATION						
BRAND NAME :						
MODEL : 1..... 4.....						
2..... 5.....						
3..... 6.....						
STANDARD NO.: (MS IEC/IEC/etc.)						
CERTIFICATE OF APPROVAL : (SURUHANJAYA TENAGA, if any)				DATE OF ISSUE:		
				VALID UNTIL:		
PRODUCT CERTIFICATION : LICENSE (SIRIM/OTHER)				DATE OF ISSUE:		
				VALID UNTIL:		
TEST REPORT NO.:				TESTING LABORATORY:		
				DATE OF ISSUE:		
COUNTRY OF MANUFACTURED:						
NAME OF MANUFACTURER:						
FACTORY ADDRESS :						

Please Tick: Yes No - Office use

- 5.1 Compliance to MS 61386-21 Yes No
- 5.2 Compliance to MS 60423 Yes No
- 5.3 Compliance to MS 60614-1 Yes No
- 5.4 Compliance to MS 60614-2-2 Yes No
- 6.0 CLASSIFICATION ACCORDING TO MECHANICAL PROPERTIES (MS 61386-21)
- 6.1 Having a testing on Resistance to Compression on Yes No
Heavy Duty Type (Class 4)
- 6.2 Having a testing on Impact Test on Heavy Duty Type (Yes No
Class4)
- 7.0 **Marking**
- 7.1 The conduit has a marking with classification code in accordance With Annex A (BS EN 50086-2-1) and shall include at least the first 4 digit:- **(e.g. 4421)** Yes No
- 7.2 The conduit is marked at preferably length of 1 meter or not longer than 3 meter and each length shall be marked at least once Yes No
- 7.3 Approved by Jabatan Bomba & Penyelamat Yes No
- 7.4 White colour for surface wiring Yes No
- 7.5 Orange coloured for concealed wiring, If Otherwise stated can used other colour Yes No
- 8.0 **All conduit fittings (accessories) shall be of heavy duty type & supplied by the same manufacturer for rigid high impact UPVC conduits** Yes No
- 9.0 **The ends of each length of rigid high impact UPVC conduits shall be Properly reamed** Yes No

10. Details of Conduits:

Item	Model	Conduit size Diameter x Length	Class of Protection	Photograph

11. Detail of Conduit Fittings Accessories:

Item	Model	Descriptions	Photograph

12. List of technical document:

12.1) Operations manual:

12.2) Maintenance manual:

12.3) Catalogue:

TECHNICAL INFORMATION

**RIGID HIGH IMPACT PVC CONDUIT &
CONDUIT FITTINGS**

E. OTHERS *(Please Specify)*

1.
2.
3.

F. PENGESAHAN

Adalah saya dengan ini mengesahkan segala keterangan yang diberikan/dikemukakan bagi produk di atas adalah benar. Jika saya didapati membuat pengakuan **PALSU**, maka tindakan seterusnya boleh diambil oleh pihak JKR ke atas diri saya.

Cop Syarikat :



Tandatangan :

Nama :

Jawatan :

Tarikh :

G. ULASAN *(Untuk Kegunaan Pejabat)*

.....
.....
.....
.....