




American Air Filter Manufacturing Sdn. Bhd.

Lot 6 Jalan Pengapit 15/19
Seksyen 15, 40000 Shah Alam,
Selangor, Malaysia.

CERTIFICATE OF CONFORMITY

Document No. : MAFP-95-901A-3 11/21
Certificate's Holder : American Air Filter Manufacturing Sdn. Bhd.
Lot 6, Jalan Pengapit 15/19,
Seksyen 15, 40000 Shah Alam,
Selangor, Malaysia
Product : Air Purifier
Trademark : AAF
Model : AstroPure 550C
Sample No. : N/A
Test Standard or Method : GB 21551.3-2010 Appendix A
Report No. : 2020SP0871R04D
Report Date : 15th Apr 2020



Approved Signatories,

Kenneth Chong Kok How
Manager
Service and Technical

Manjula A/P Rajakumar
Manager
Quality and Sustainability

This Certificate of Conformity refers only to samples as stated in first page. This Certificate of Conformity shall not reproduce, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from the management of AAF Manufacturing Sdn. Bhd. Please refer the last page for Conditions Relating to the Use of Certificate of Conformity.

SUMMARY

We hereby certify that virus elimination effect on model AstroPure 550C air purifier has been tested accordance to testing standard GB 21551.3-2010 Appendix A.

PRODUCT SPECIFICATION

Rated voltage or voltage range	: 220 – 240 V
Rated current or current range	: 0.33 A
Rated power or power range	: 72 W
Rated frequency or frequency range	: 50/60 Hz
Clean air delivery rate (particulate matter)	: 700 CMH
Dimensions (H x W x D)	: 667 x 370 x 370 mm

SAMPLE PHOTO



(End of Page)

Asia Sales Office

American Air Filter Manufacturing Sdn. Bhd.
(HQ - Malaysia)
(Penang - Malaysia)

Tel : +60 3 5039 7777
Tel : +60 4638 4100

For enquiries email us at
enquiry@aafasia.com

AAF has a policy of continuous product research and improvement and reserves the right to change design and specifications without notice.

© AAF Malaysia

This Certificate of Conformity refers only to samples as stated in first page. This Certificate of Conformity shall not reproduce, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from the management of AAF Manufacturing Sdn. Bhd. Please refer the last page for Conditions Relating to the Use of Certificate of Conformity.

TEST RESULT

GB 21551.3-2010 Appendix A					
Test space: In the 30m ³ experimental space					
Reaction Time	Virus	Test No.	Air Virus Content (TCID ₅₀ /m ³)		Removal Rate (%)
			Before	After	
1h	Influenza A virus H1N1 (MDCK)	1	1.94 x 10 ⁶	6.00 x 10 ²	99.91
		2	1.44 x 10 ⁶	4.88 x 10 ²	99.90
		3	1.73 x 10 ⁶	6.58 x 10 ²	99.91

(End of Page)



This Certificate of Conformity refers only to samples as stated in first page. This Certificate of Conformity shall not reproduce, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from the management of AAF Manufacturing Sdn. Bhd. Please refer the last page for Conditions Relating to the Use of Certificate of Conformity.

CONDITIONS RELATING TO THE USE OF AAF CERTIFICATE OF CONFORMITY

1. Certificate of Conformity will be issued in respect of Testing Services conducted and shall relate only to the Sample actually tested. AAF makes no warranty whatsoever and shall not represent in any manner that any duplication or mass production of the Product is same as the Sample actually tested or that AAF has tested any of the duplicated or mass-produced Product.
2. The Certificate of Conformity shall not be amended, changed, varied or modified in any manner whatsoever.
3. If the Certificate of Conformity is to be furnished to any third party or to the public, each such Certificate of Conformity shall be furnished in full, legible and in its entirety.
4. The Certificate of Conformity shall not be reproduced and shall not in any event be used for any advertising purposes or whatsoever without written approval from the AAF Management of Lot 6, Jalan Pengapit 15/19, Seksyen 15, 40000 Shah Alam, Selangor Darul Ehsan.
5. Customer is not permitted to use any AAF Malaysia, AAF International or other AAF's subsidiaries logo[®] or words on packaging, sample's manual, technical specification, brochures flyers or any other means without the prior written approval from the Management of AAF.
6. In the event the Customer is found in breach of this provision, AAF Malaysia, AAF International and/or other AAF's subsidiaries without prejudice to any other rights and remedies may take whatever action necessary including but not limited to:
 - a) Informing and placing a notice in the media;
 - b) Obtaining an injunction from Court (cost on a solicitor-client basis to be borne by the Customer);
 - c) Instructing the Customer to withdraw and recall the advertisement, statement or document in question and advertise a clarification and apology to AAF Malaysia, AAF International and/or other AAF's subsidiaries twice in a national publication of AAF's choice at the Customer's sole cost;
7. Certified true copies of the Certificate of Conformity may be issued upon request by the Customer upon payment of the relevant fee.
8. Corrections to Certificate of Conformity shall only be allowed within 6 months from issuance date of the Certificate of Conformity and shall be limited to maximum 3 times, after either case whichever occurs earlier, a new Certificate of Conformity shall be issued and replace the previous one (having error(s) or lack of information). Issuance of Supplementary Report to the original Certificate of Conformity shall be for the followings;
 - a) Misprints and typo errors
 - b) Missing technical information
 - c) Test data not reported
 - d) Mistake in reporting of test data